



CUSTOMER APPROVAL

APPROVED BY: _____

DATE: _____

NOTES:

1. CUSTOMER IS CITY OF WHEAT RIDGE. LOGO TO BE SPECIFIED: _____.
2. THIS ASSEMBLY IS RATED FOR A STATIC DESIGN LOAD OF 22,500 LBS. [100,080 N] OVER A 10 [254] X 20 [508] AREA AND MUST PASS A MIN. STATIC TEST LOAD OF 33,750 LBS. [150,120 N].
3. ELECTRONIC MARKER SYSTEM FREQUENCY 101.4kHz.
4. LID TO BE SECURED WITH 12 GAUGE WIRE.

04/07/15 87# 30kg LC S

N.T.S. QUAZITE® 11 X 18 X 12 A

BOX & COVER ASSEMBLY 1/4

W/ (3) TEST POINTS & (2) PULL SLOTS

109298 1 1 PG1118Z545



LG-B03 STREET LIGHT PULL BOX

STREET LIGHT PULL BOX

APPROVED BY: SN _____ APPROVE DATE 10/2016

DETAIL
CODE

LG